

TABLE 3			
SUBPART X MISCELLANEOUS TREATMENT UNITS			
UNIT I.D. NUMBER	MAXIMUM ALLOWABLE CAPACITY	SECONDARY CONTAINMENT	PERMITTED HAZARDOUS WASTE CODES
BRA-DRYR-101	Nip Containment, 120 gallons ¹ Pan Containment, 680 gallons ¹	9039 gallons ³	D002,D004, D005, D006, D007, D008, D009, D010,D011, F999
BRA-DRYR-102	Nip Containment, 120 gallons ¹ Pan Containment, 680 gallons ¹		
BRA-DRYR-201	Nip Containment, 120 gallons ¹ Pan Containment, 680 gallons ¹		
BRA-EVAP-101 ²	Shut-in volume, 1200 gallons		
BRA-EVAP-201 ²	Shut-in volume, 1200 gallons		
¹ These volumes are approximate because brine is not expected to be collected in the dryers during operations or idle periods.			
² Heat exchangers are considered part of the Evaporator Package and will not be listed as a separate unit.			
³ The secondary containment volume includes the floor area of the BRA with dike wall and curbs as well as PUB-SUMP-101 and 102.			